

佛山出入境检验检疫局检验检疫综合技术中心
INSPECTION AND QUARANTINE COMPREHENSIVE TECHNOLOGY CENTRE OF
FOSHAN ENTRY-EXIT INSPECTION & QUARANTINE BUREAU

检测报告

TEST REPORT

报告编号: 25201400064

共 5 页 第 4 页

Report No:

Page 4 of 5

EN 14411:2012 Ceramic tiles – Definitions, classification, characteristics, evaluation of conformity and marking Annex K. Requirements for dry-pressed ceramic tiles of Group BIII ($E_b > 10\%$)					
条款 Clause	性能 Properties	检验方法 Test Method	要求 Requirements	检验结果 Results	判定 Verdicts
A	尺寸和表面质量 Dimensions and surface quality				
A.1	长度 Length 每块砖的平均尺寸相对于工作尺寸的允许偏差 The deviation, of the average size for each tile (2 sides) from the work size	EN ISO 10545-2	$\pm 0.5\%$	$+0.02\% \sim +0.11\%$	P
			$\pm 2.0\text{mm}$	$+0.1\text{mm} \sim +0.4\text{mm}$	P
	宽度 Width 每块砖的平均尺寸相对于工作尺寸的允许偏差 The deviation, of the average size for each tile (2 sides) from the work size	EN ISO 10545-2	$\pm 0.75\text{mm}$	$0 \sim +0.2\text{mm}$	P
A.2	厚度 Thickness				
	应声明厚度 The thickness shall be specified	—	声明厚度 Declared thickness	7.7mm	—
	每块砖厚度的平均值相对于工作尺寸的最大允许偏差 The permissible deviation, of the average thickness of each tile from the work size thickness	EN ISO 10545-2	$\pm 0.5\text{mm}$	$0 \sim +0.1\text{mm}$	P
B	物理性能 Physical properties				
B.1	吸水率 质量分数 Water absorption Percent mass fraction	EN ISO 10545-3	$E_b > 10\%$	17.1%	P
			单个值不小于 9% Individual minimum 9%	16.7%~17.6%	P
B.2	破坏强度/N Breaking strength, in N	EN ISO 10545-4	≥ 600	663	P
B.3	断裂模数/(N/mm ²) Modulus of rupture, in N/mm ² 不适用于破坏强度 $\geq 3000\text{N}$ 的陶瓷砖 Not applicable to tiles with breaking strength $\geq 3000\text{N}$	EN ISO 10545-4	≥ 12	22.6	P
B.4	耐磨性 Abrasion resistance 用于地面的有釉砖的表面耐磨性 Resistance to surface abrasion of glazed tiles intended for use on floors	EN ISO 10545-7	报告耐磨级别 Report abrasion class	4 级 Class 4	—
			报告耐磨转数 Report cycles passed	2100	—
B.6	抗热震性 Thermal shock resistance	EN ISO 10545-9	应通过此项测试 Pass	样品经试验, 无炸裂或裂纹 Fully resistance	P
B.7	抗釉裂性: 有釉砖 Crazing resistance: glazed tiles	EN ISO 10545-11	应通过此项测试 Pass	样品经试验, 无裂纹或剥落 Fully resistance	P

FSIQC-T 2(1)/A

INSPECTION AND QUARANTINE COMPREHENSIVE TECHNOLOGY CENTRE
OF FOSHAN ENTRY-EXIT INSPECTION & QUARANTINE BUREAU

CERTIFICATE
Of Conformity

Certificate No: 25201400064

Applicant:

Address of Applicant:

Product: INTERIOR WALL TILES

Type designation: NC1400, Y1A04001, NC1401, NC1406

Technical data: Dry-pressed ceramic tiles for interior wall finishes, with water absorption $E_b > 10\%$, Group BIII, 40cm \times 10cm, Flat, Glazed

正本
申请人存

The submitted samples of the above product have been tested for CE marking according to the following European Directives:

(EU)No.305/2011-the Construction Products Regulation

Standard used for showing compliance with the essential requirements in the specified directive:

Standard Test report Issued by Date
EN 14411:2012 25201400064 IQTC of FSCIQ Jan. 28, 2014

The referred test report shows that the product complies with standard recognized as giving presumption of compliance with the essential requirements in the specified EU Directive.

After preparation of the necessary technical documentation as well as the conformity declaration the CE marking as shown below can be affixed on the product. Other relevant Directives have to be observed.

This certificate is **NOT** valid for: i) uses in suspended ceilings; ii) uses subject to requirements against accidental fall of objects on to transit areas; iii) uses subject to dangerous substances regulations; iv) uses in vehicular circulation areas.

This document is the property of Inspection and quarantine comprehensive technology centre of Foshan Entry-exit Inspection & Quarantine Bureau, and it is not transferable. Only the applicant may reproduce this certificate.



YUAN FANGLI
Director



Issue Date: Jan. 28, 2014
Expiration Date: Jan. 27, 2015

Note: This certificate is part of the full report and should be read in conjunction with it.

INSPECTION AND QUARANTINE COMPREHENSIVE TECHNOLOGY CENTRE OF FOSHAN ENTRY-EXIT INSPECTION & QUARANTINE BUREAU
2/F, Building 18, Lanshi International Metal Exchange Center, Kuiqi Road, Chancheng District, Foshan, Guangdong, China (528000)
TEL: 86-757-83960558 FAX: 86-757-83827971

佛山出入境检验检疫局检验检疫综合技术中心
INSPECTION AND QUARANTINE COMPREHENSIVE TECHNOLOGY CENTRE OF
FOSHAN ENTRY-EXIT INSPECTION & QUARANTINE BUREAU

检测报告
TEST REPORT

报告编号: 25201400064
Report No:

共 5 页 第 2 页
Page 2 of 5

样品名称 Name of sample	釉面内墙砖 INTERIOR WALL TILES	名义尺寸 Nominal size (N)	40cm×10cm
表面特性 Nature of the surface	有釉砖 Glazed (GL)	工作尺寸 Work size	400mm×100mm×7.7mm
类别 Group	BIII	预期用途 Intended use	室内墙面 Interior wall finishes
样品标记 Mark of samples	NC1400	样品数量 Quantity of samples	15 块 15 Pieces
委托单位 Applicant		委托单位地址 Address of applicant	
委托单位电话 Telephone of Applicant		委托单位传真 Fax of Applicant	
样品来源 Source of Samples	委托单位自送样品 Samples selected by applicant	接样日期 Received on	02/01/2014
检验依据 Test Standard	EN 14411:2012 Ceramic tiles – Definitions, classification, characteristics, evaluation of conformity and marking Annex K Requirements for dry-pressed ceramic tiles of Group BIII ($E_a > 10\%$)		
检验结论 Conclusion of Test	样品经检验,所检验项目的检验结果符合 EN 14411:2012 标准中附录 K 的规定。 The results conform to the requirement of Annex K of standard EN 14411:2012 with respect to the test items.		
检验单位盖章 Stamp of Test Unit	 日期: 28/01/2014 Date:	检验单位联系方式 Address of Test Unit	地址: 广东省佛山市禅城区魁奇一路澜石(国际)金属交易中心十八座二楼 Address: 2/F, Building 18, Lanshi International Metal Exchange Center, Kuiqi Road, Chancheng District, Foshan, Guangdong, China (528000) 电话 (Tel): 86-757-83960558 86-757-83827991 传真 (Fax): 86-757-83827971 邮箱 (E-mail): fsiqtc@163.com

	www.fsiqtc.com	网址 (url): http://www.fsiqtc.com/
声明 Notes	<p>1、我们已尽所知所能实施上述检验，不能因签发本报告而免除有关各方根据合同和法律所承担的责任和义务。 All inspections are carried out conscientiously to the best of our knowledge and ability. This report does not in any respect absolve the other related parties from his contractual and legal obligations.</p> <p>2、未经本实验室书面许可，不得部分复制本报告。 This report shall not be reproduced, except in full, without the prior written approval from the issuing laboratory.</p> <p>3、本报告仅是样品的检测结果。 The results in this report apply to the samples only.</p>	

检验负责人
Tested by

肖 13-12

审核
Inspected by

S. 13-12

批准
Approved by

13-12

FSIQC-T 2(1)/A